

Bedienungsanleitung für direktgesteuerte Magnetventile

Diese Einbau- und Bedienungsanleitung muss unbedingt beachtet werden. Die Einhaltung der Grenzwerte für Drücke und Temperaturen und die Beachtung von Hinweisen für das Gerät gemäß Datenblatt und Lieferschein ist Voraussetzung für eine einwandfreie Funktion mit langer Lebensdauer. Bei Anwendungen im Sicherheitsbereich beachten Sie auch die nationalen Bestimmungen. Bei Nichtbeachtung dieser Hinweise entfällt jegliche Haftung unsererseits, ebenso erlischt die Garantie auf Geräte und Zubehörteile.

► **Funktion:**

Direktgesteuerte Ventile sind in Standardausführung immer stromlos geschlossen. Wird durch Anlegen einer Spannung die Magnetspule erregt, öffnet der Anker direkt den Ventilsitz. In Ruhestellung drückt die Schließfeder die Sitzdichtung auf den Ventilsitz, das Ventil ist geschlossen. Mit größerem Ventilsitz verringert sich der zulässige Betriebsdruck oder die Magnetleistung muss verstärkt werden.

► **Lagerung und Transport:**

Die Ventile sind sachgemäß und geschützt an einem sauberen, trockenen Ort zu lagern. Für das Handling schwerer Ventile sind ausschließlich die dafür vorgesehenen Ösen oder geeignete Lastentragebänder am Ventilkörper zu verwenden. Niemals den Antrieb als Tragegriff oder Hebelarm benutzen!!!

► **Einbau:**

Die Einbau- bzw. Durchströmrichtung des Ventils ist zu beachten. Das Ventil ist für eine Durchströmrichtung ausgelegt und in seiner Funktion festgelegt. Bei verkehrtem Einbau ist die Funktion nicht gewährleistet. Das Risiko wird durch dauerhaft lesbare, eingravierte Markierungen an den Anschlüssen verhindert. P für Eingang, A für Ausgang und R für Rücklauf bzw. bei 3/2-Wegeventilen für 2. Ausgang. Die Einbaulage ist nur mit stehendem Antrieb in waagerechter Leitung vorgeschrieben, es sei denn, aus anderen Dokumenten (Datenblatt, Angebot) geht Gegenteiliges hervor. Pfeilrichtung, bzw. Anschlusskennzeichnung (P, A, R) am Gehäuse mit Fließrichtung des Mediums vergleichen! Zur Realisierung bestimmter Schaltfunktionen bei 3/2-Wege-Ventilen sind die Anschlussbelegungen im für die jeweilige Ventiltypen gültigen Datenblatt zu beachten. Datenblätter sind u.a. verfügbar unter www.ventiltechnik.de.

Vor der Montage, Rohrleitungen mit Druckintervallen durchspülen. Nach DIN 3394 sowie DIN EN 161 ist jeder Absperrarmatur ein Schmutzfänger vorzuschalten um die einwandfreie Funktion im Betrieb von neutralen Medien zu gewährleisten. Durch Verunreinigungen können Verstopfungen von kleinen Bohrungen wie an der Vorsteuer- bzw. Abbaubohrung entstehen und die Funktionen wie Schließen/Öffnen des Ventils einschränken bis blockieren.

Wird ein Ventil mit Muffenanschluss montiert, Spule bitte nicht als Hebel benutzen. Anschlussflansche inkl. Dichtungsmaterial und Verbindungselemente entsprechen den Standards aus dem Rohrleitungsbaubereich und obliegen der Verantwortung des Anlagenbauers. ► **Inbetriebnahme:**

In Abhängigkeit des Einsatzgebietes können medienbedingt höhere bzw. niedrige Oberflächentemperaturen als Umgebungstemperaturen an den Armaturengehäusen auftreten. Im Anlagenbau werden normalerweise Leitungen mit hohen Temperaturdifferenzen zur Umgebungstemperatur aus energetischen Gründen entsprechend isoliert. Diese Isolierung sollte ebenfalls das Gehäuse der Industriearmatur mit einschließen. Die Magnetspulen dürfen zum einen aus thermischen Gründen (Wärmestau) und des weiteren aus Gründen der einfachen Wartung nicht mit isoliert werden. Durch Isolierung des Gehäuses wird das eventuelle Risiko der Verbrennungsgefahr ausgeschlossen. Die Entscheidung bzgl. Isolierung trifft der Anlagenbauer und fällt somit in seinen Verantwortungsbereich. Abschließend bleibt ein geringes Restrisiko durch erhöhte Oberflächentemperatur an der Magnetspule, dass abhängig von der Schalthäufigkeit ist. Achtung: Oberflächentemperatur kann größer 100°C sein! **Achtung:** Wechselspannungsmagneten nur auf dem Tubus sitzend in Betrieb nehmen. Das Betreiben ohne Eisenteil führt zu einem höheren Strom durch die Wicklung als zugelassen und damit zur thermischen Selbstzerstörung des Magneten. Einige Ventile sind mit einer einstellbaren Schließregulierung ausgerüstet, die werksseitig für die sichere Ventillfunktion bzgl. Schließzeit bei einer Medienviskosität bis 22 mm²/s eingestellt wird. Die Einstellung erfolgt mittels gekonterter Einstellschraube und kann ggf. anlagenspezifisch durch den Kunden verstellt bzw. nachjustiert werden. Hieraus entsteht das Risiko, dass bei unsachgemäßer Behandlung die Einstellschraube im Betrieb komplett entfernt werden könnte und Medium durch die Steuerbohrung nach außen treten könnte.

Weiterhin ist die Schließzeit werksseitig so eingestellt, dass bis zur angegebenen Viskosität des Mediums keine oder nur geringfügige Druckschläge für das Rohrleitungssystem auftreten. Eine Verstellung seitens des Kunden / Anlagenbetreibers kann aber (abhängig von der Medienviskosität) notwendig sein. Deshalb darf die Verstellerschraube nicht festgesetzt werden. Es liegt somit in der Verantwortung des Anlagenbetreibers vom Fachpersonal die Verstellung bei der Inbetriebnahme der Anlage vornehmen zu lassen und damit das Risiko der kompletten Entfernung dieser Verstellerschraube zu verhindern.

Beim Betreiben der Industriearmatur innerhalb der Anlage kommt es strömungsbedingt zu elektrostatischen Aufladungen. Diese werden normalerweise im Anlagenbau durch eine Kabelverbindung separat oder über das elektrisch leitende Rohrleitungssystem durch Erdung abgeleitet. An der Industriearmatur befinden sich am Gehäuse Gewindebohrungen für einen eventuellen Kabelanschluss.

In Abhängigkeit des Einsatzes und unter dem Aspekt des Energieverbrauchs werden auch NO-stromlos geöffnete Ventile ausgeführt, d.h. bei Stromausfall öffnen sich diese Ventile. Optional können diese Ventile mit zusätzlicher Handbetätigung ausgeführt werden, um sie bei Stromausfall manuell zu verschließen, bzw. bei NC-Ventilen zu öffnen.

Ob das Ventil bei Stromausfall in die geöffnete oder geschlossene Stellung fahren muss, ist abhängig von der Anlage und ist nach dem Sicherheitsprinzip der Gesamtanlage zu wählen. Es fällt somit in den Verantwortungsbereich des Anlagenbauers. **Achtung:** Wechselspannungsmagneten nur auf dem Tubus sitzend in Betrieb nehmen. Das Betreiben ohne Eisenteil führt zu einem höheren Strom durch die Wicklung als zugelassen und damit zur thermischen Selbstzerstörung des Magneten.

► **Elektrischer Anschluss:**

Die Magnetsysteme des Standardprogramms haben entweder einen Steckeranschluss oder einen Klemmkasten an der Magnetspule.

Vor dem Anschluss der Stromzufuhr, die vorgeschriebene Stromart und Spannung auf dem Typenschild und Lieferschein beachten.

Spannungstoleranz +5%/-10%. Die Einschaltdauer beträgt 100% ED. Als Betriebsdauer (DB) gilt die Funktion, bei der die Spule solange eingeschaltet bleibt bis die Belastungstemperatur erreicht ist. Elektrische Anschlüsse vor Dauerfeuchtigkeit schützen.

Bei Freiluftmontage eine ausreichende Abdeckung vorsehen. Die Schutzart IP 65 besagt, dass das Gerät nur für eine kurzfristige Feuchtigkeitsbelastung ausgelegt ist. Elektrische Anschlüsse nur durch Fachpersonal vornehmen. Bei Magnetspulen, welche nur in Verbindung mit einem beigelegten Gleichrichter oder einer Schaltelektronik arbeiten, muss dieses zwingend angeschlossen werden. Maximales Anzugsmoment bei Magnet .182 beträgt 1,2Nm!

► **Mögliche Störfälle:**

Fließrichtung, Spannung, Einsatzort und Betriebsdruck überprüfen!

- | | |
|--|--|
| <ul style="list-style-type: none"> • Ventil schließt nicht - Anker blockiert - Nennspannung liegt noch an - Falsche Einbaulage - Pfeilrichtung mit Durchflussrichtung nicht identisch - Falsche Sitzdichtung | <ul style="list-style-type: none"> • Ventil öffnet nicht - Betriebsdruck zu hoch - Anker zieht nicht an - Anschlussspannung ist unterbrochen oder nicht ausreichend - Magnetspule oder Gleichrichter defekt - Nennspannung und Spulenspannung unterschiedlich - Anker blockiert im verschmutztem Ankerraum (wenn der Anker die Hubendlage nicht erreicht, führt dieses bei erregter Wechselstrom-Spule schon nach kurzer Zeit zum Ausfall der Spule (thermische Überlastung)) |
|--|--|

► **Eingriffe**

dürfen nur durch Fachpersonal und mit geeignetem Werkzeug erfolgen. Befindet sich das Ventil noch in der Gewährleistung, so darf ein Eingriff erst nach Rücksprache mit GSR erfolgen, ansonsten erlischt die Gewährleistung. Bei abweichenden Ventilausführungen vom Standard, bedingt durch die Ventiloptionen verschiedener Art oder Ventil-Sonderausführungen, halten Sie sich bitte an die technischen Angaben gemäß Lieferschein oder vorausgegangenem Angebot. In diesen Fällen kann diese Bedienungsanleitung nur bedingt Verwendung finden.

► **Wartung**


Die Wartung hängt von den Betriebsbedingungen ab. Es wird empfohlen, das Ventil regelmäßig zu reinigen, wobei sich die Zeitabstände nach dem Medium und den Betriebsbedingungen richten. Das Ventil sollte mindestens alle 6 Monate auf Leckage nach außen und auf seine Funktion hin kontrolliert werden. Während der Wartung sollten die Komponenten auf übermäßigen Verschleiß überprüft werden. Für die Überholung der GSR-Produkte sind komplette Service-Sets mit internen Teilen als Ersatzteilsätze erhältlich. Treten Schwierigkeiten bei Einbau, Betrieb oder Wartung auf sowie bei Unklarheiten, ist mir GSR Rücksprache zu halten. Zur Erhaltung der Funktionsfähigkeit des Ventils ist es in regelmäßigen Abständen zu betätigen.

► **Hinweise zur Druckgeräterichtlinie:**

Alle Ventile sind konstruiert und gefertigt in Übereinstimmung mit der EU-Richtlinie 97/23/EG (Druckgeräterichtlinie) Geräte, welche keine CE-Zeichen am Gehäuse besitzen, fallen unter Artikel 3 Absatz 3 der Richtlinie. Sie sind anhand der „guten Ingenieurpraxis“ ausgelegt und hergestellt und dürfen keine CE-Kennzeichnungen tragen. **Kennzeichnung des Gerätes:** **keine**

Stand 01/2006 – Irrtum und Änderungen vorbehalten!

GSR Ventiltechnik GmbH & Co. KG
 Im Meisenfeld 1
 D-32602 Vlotho



Operating instructions for direct acting solenoid valves

It is essential to follow these installation and operating instructions. To ensure perfect functioning and long service life, the limit values for pressures and temperatures must be observed, as must the information contained in the data sheet and delivery note.

You must also comply with national regulations when in use in safety areas. Failure to follow these instructions will exempt us from all liability and will invalidate the warranty on equipment and accessories.

► **Function:**

Standard direct acting solenoid valves are always closed when de-energised (NC). If the solenoid is energised by applying a voltage, the plunger is lifted opening the valve. In the de-energised position the plunger is forced onto the valve seat by a spring, closing the valve. With a larger seat diameter, the permitted operating pressure decreases and the magnet strength must be increased.

► **Storage and transportation:**

The valves must be properly protected and stored in a clean, dry area. For the handling of heavy valves, only use the eye bolts provided for this purpose and/or suitable certified slings on the valve body. Never use the actuator as a carrying handle or lever!!!

► **Installation:**

When installing, the direction of the medium which flows through the valve, must be taken into consideration. The valve is designed to function in a specific direction only, and its function is defined. If the valve is not correctly installed, it will not function. To prevent the risk of this happening, the valve is engraved with permanently legible markings on the connections. P for input, A for output and R for return flow or , in the case of 3/2-way valves, for the second output. Install the valve only with upright actuator in horizontal direction unless there is the opposite indicated in other documents like data sheet or quotation. Always take into consideration the direction of the arrows or the connection marking (P, A, R) on the housing, in respect to the flow of the medium. For the carrying out of specified switching functions at 3/2-way valves the terminal pin assignments are stated in the relevant data sheets. Data sheets are available on our homepage www.ventiltechnik.de.

Before installation, rinse through pipes with pressure intervals. In accordance with DIN 3394 and DIN EN 161, a strainer must be fitted upstream of every shut-off valve so as to ensure smooth functioning with neutral media. Dirt may cause blockage of small orifices such as the pilot or reduction orifice, and may restrict or prevent functions such as closing/opening the valve.

If a valve is installed with a sleeve connection, please do not use the solenoid as a lever. Connection flanges, inclusive of sealing material and connection elements, conform to the standards from pipeline manufacturing and are the responsibility of the system engineer.

► **Putting into operation:**

Depending on the area of use, surface temperatures higher or lower than the ambient temperatures may occur on the valve housing. In system engineering, pipes with large temperature differences relative to the ambient temperature are usually insulated accordingly to save energy. This insulation should also include the housing of the industrial fittings. The solenoid must not be insulated both for thermal reasons (heat build-up) and also to permit easy maintenance. Insulating the housing excludes the possible risk of burns. The decision regarding insulation is taken by the system engineer and is thus his responsibility. Finally, there is a small residual risk caused by high temperature on the solenoid, which depends on the frequency of operation. Caution: surface temperature can be above 100°C! **Attention:** Coils with alternating voltage are only to be operated when they are fitted to a solenoid tube. The operation without such a tube could lead to a higher flow of voltage through the coil than approved and therefore leading to a thermic self-destruction of the coil.

Some valves are equipped with adjustable closing regulation, which is set at the factory for reliable valve functioning with regard to closing time at a viscosity of the medium of up to 22 mm²/s. The setting is made using a locked adjustment screw and can, if required, be changed and readjusted by the customer to suit the particular system. This entails the risk that, if handled incorrectly, the adjustment screw might be removed completely and the medium would be able to escape to the outside through the control orifice.

Furthermore, the closing time is set at the factory so that up to the stated viscosity of the medium no, or only minimal, pressure surges occur in the pipe system. Adjustment by the customer/system operator may, however, be necessary (depending on the viscosity of the medium). For this reason, the adjustment screw must not be fixed. It is therefore the responsibility of the system operator to have the adjustment made by expert staff when the system is put into operation and thereby prevent the risk of the adjustment screw being removed completely.

When operating the industrial valve within a system, electrostatic charges may occur due to the flow of the medium. These charges are normally discharged to earth via a cable connection or via the electrically conductive pipe system. The industrial valve has a threaded hole in the housing to permit connection of a cable.

Depending on the area of use, and for reasons of energy consumption, there are also NO valves that are open when de-energised, i.e. in the event of a power failure these valves open. These valves can optionally be equipped with additional manual operation to allow them to be closed manually during a power failure, or to allow opening in the case of NC valves.

The choice of the open or closed position during power failure must be made according to the particular system and with safety in mind. This decision is therefore the responsibility of the system engineer.

► **Electrical connection:**

The solenoid systems in the standard range have either a plug-in connection or a terminal box on the solenoid.

Before connecting the power supply, check the specified type of current and voltage on the rating plate and delivery note.

Voltage tolerance +5%/-10%. The valves are designed for continuous duty. The operating time is the function in which the solenoid remains energised until the load temperature is reached. Protect electrical connections against continuous moisture.

If installed outdoors, provide adequate covering. IP 65 enclosure protection means that the unit is only designed for short exposure to moisture. Electrical connections must only be made by qualified staff. In the case of solenoids that only operate with accompanying rectifier or switching electronics, it is obligatory for these to be connected. The maximum tightening torque for coil .182 is 1,2 Nm!

► **Possible malfunctions:**

Check the direction of flow, voltage, place of use and operating pressure!

- | | |
|--|--|
| <ul style="list-style-type: none"> ● Valve does not close - dirt in the control orifices - plunger is sticking - rated voltage is not present - incorrect installation position - direction of arrow is not identical with direction of flow | <ul style="list-style-type: none"> ● Valve does not open - diaphragm or plunger is defective - load relief orifice is blocked (inspect the seal or screw connection in the output) - plunger does not rise (audible knocking or "clicking") - connection voltage has been interrupted or is insufficient - solenoid or rectifier is defective - plunger is sticking in a blocked tube. (When the anchor does not reach the stroke end position, this causes the coil to fail (thermal overload) after a short time if the alternating current solenoid is energised) - rated voltage and coil voltage are different |
|--|--|

► **Action**

Action must only be taken by qualified staff and using suitable tools. If the valve is still under warranty, you must consult GSR before taking any action, failure to do this will result in the termination of the warranty. When added options are present and the valve differs from the standard, due to the different possibilities and/or of the valves special functions, please follow the technical data as shown in the delivery note or preceding offer. In this case these operating instructions only apply with limitations.

► **Maintenance**

The performance of maintenance on the valve depends upon the operating conditions. It is recommended to clean the valve at regular intervals whereby the interval is depending upon the medium and the operating conditions. The valve should be checked at least every 6 months to see if it is functioning correctly and if it has any outward leakage. Whilst undergoing maintenance, the various components should be inspected for excessive wear. For the servicing of GSR products, we offer a complete service set which consists of the appropriate spare parts. If difficulties arise during the fitting, operation or maintenance as well as any uncertainty reference the valve, it is advised that contact is made with GSR for further information. In order to maintain the efficiency and function of the valve it is recommended that the valve be actuated at regular intervals.

► **Information about the Pressure Equipment Directive:**

All valves are designed and manufactured in accordance with the EU Directive 97/23/EC (Pressure Equipment Directive). Equipment that has no CE mark on the housing comes under Article 3 Paragraph 3 of the directive. They are designed and manufactured on the basis of "good engineering practice" and are not allowed to carry a CE mark. **Labelling of the device:** none

State 01/2006 – Errors excepted, subject to change!

